



CITY OF PORTLAND

OFFICE OF MANAGEMENT AND FINANCE

Sam Adams, Mayor
Kenneth L. Rust, Chief Administrative Officer
Jeffrey B. Baer, Director, Bureau of Internal Business Services

Christine Moody
Chief Procurement Officer
Procurement Services

1120 S.W. Fifth Avenue, Rm. 750
Portland, Oregon 97204-1912
(503) 823-5047
FAX (503) 823-6865
TTY (503) 823-6868

July 8, 2010

ADDENDUM NUMBER 5 Bid Number 111923

Laurelhurst Pond Restoration
Bids Due: June 15, 2010
By: 2:00 P.M.

This addendum provides changes to the plans and specifications for the above-entitled project to be considered by each bidder. This addendum shall be included in the bid and, when closing the contract, will be a part thereof. Any changes made by this addendum to said plans and specifications offset only the portion of the plans, words or paragraphs specifically mentioned herein, and the balance of the plans and/or specifications remain in full force. It is the responsibility of all bidders to conform to this addendum.

| Item No. | Location | Change |
|----------|---|--|
| 5.01 | Summary of Work Section 01010.1.5.A and Dredging, Section 35023.3.3.C.2 | The Bureau of Parks and Recreation working with Bureau of Environmental Services will obtain a discharge permit and monitor as needed for water going into Combined Sewer. Contractor remains responsible to meet Total Suspended Solids content at not more than 300mg/L per Bid Specifications, section 35023.3.3.C.2. Monitoring of TSS to be by Parks working with BES. |
| 5.02 | Bid Book, Specifications | Contractor has the option to deposit dredged material at the City's Thomas Cully property at no disposal cost. This is the former Killingsworth Fast Disposal land fill with the entrance at 5690 NE 75 th Avenue (just off of NE Killingsworth). Contractor to be responsible for all costs associated with hauling to this site. Contractor will be issued a key and will be required lock up after 3:00 p.m. on weekdays and on Saturdays. |
| 5.03 | Specifications Sections 352023.3.1.C and 352023.3.3.A & C.1 | Lined or watertight dump trucks are not required as long as soil can be transported and the material will not slosh over the edges and the transportation of material over city and state roads will still meet the regulations governing transport of material. Contractor is responsible for making sure material is transportable in open bed dump trucks and is still subject to regulations governing transport of material and clean roads. |


An Equal Opportunity Employer

To help ensure equal access to programs, services and activities, the Office of Management & Finance will reasonably modify policies/procedures and provide auxiliary aids/services to persons with disabilities upon request.

| | | |
|------|-------------------------------|--|
| 5.04 | Bid Book, Description of Work | Contractors are allowed to work Saturdays 8:00 a.m. to 5:00 p.m. The exceptions are: Hours will be 8:00am to 4:00pm for the following days: Saturday August 7 th , Saturday August 14 th , Saturday August 21 st , and Saturday August 27. |
|------|-------------------------------|--|

Please direct all questions and concerns to Michael Perrie, Sr. Procurement Specialist at (503) 823-6130.

End of Addendum



Christine Moody
Chief Procurement Officer
CM/mp